4 Turkey Hill Road Newtown, CT 06470 Tel (203) 270-4300 Fax (203) 426-9968

Fred Hurley,

Director



TOWN OF NEWTOWN WATER AND SEWER AUTHORITY

Marianne Brown,
Chairman
Richard Zang
Louis Carbone
George Hill
Alan Shepard
Eugene Vetrano
Carl Zencey

THESE MINUTES ARE SUBJECT TO APPROVAL BY THE WATER AND SEWER AUTHORITY

The Water and Sewer Authority held a regular meeting, Thursday, February 7, 2019 at the Waste Water Treatment Plant, 24 Commerce Road, Newtown, CT. Marianne Brown called the meeting to order at 7:05pm.

Present: Gene Vetrano, Carl Zencey, Marianne Brown

Absent: Lou Carbone, Dick Zang, Alan Shepard, George Hill

Also Present: Director of Public Work Fred Hurley, Julio Segarra and Mike Burke of Suez Water Environmental Services, Kurt Mailman of Fuss & O'Neill and Peter Alagna

Public Participation - None

Minutes – Tabled due to lack of quorum

Report by Suez Water Environmental Services – The plant is running well. They just submitted their reports to the state and there are no violations. A pump was changed at the Sandy Hook pump station. It was clogged with rags and burnt the motor out. All the other stations are running fine.

Report by Public Works Director – Fred Hurley suggested that he and Julio Segarra be authorized to write a letter to the BOE Director of Facilities, suggesting a filter system for the High School. A year or so ago they had a huge blockage that when it released it almost overflowed the Sandy Hook Pump Station.

Fred Hurley also reported that in discussing with Attorney Grogins, they cannot find anything that says they cannot levy benefit assessments for the water improvements. This opens the avenue legally to recapture those funds and repay the sewer fund for the loan.

UNFINISHED BUSINESS

Water Pollution Control Plan – Tabled due to lack of quorum

Sandy Hook Pump Station – Kurt Mailman presented the proposed upgrades to the Sandy Hook pump station (Attachment A). Julio Segarra asked about the backup floats. The current system has back up floats and it doesn't matter what size pump, they are autonomous. He doesn't believe that we will need this item. He asked for an open assist on the hatch as well as the fall protection.

The bypass pump, Fuss & O'Neill would give the contractor the high and low flows and it would be up to them to provide a pump that could handle the flow. Because Fred and Julio will be GCing the project

they have flexibility. They can put a line in and have it monitored by SCADA to save the cost of having it manually monitored.

Financials – not discussed

NEW BUSINESS

I&I – There are concerns about the uptick in flow at the Hawleyville Pump Station. Julio provided a graph (Attachment B) which shows an uptick swing in June. They are not sure if this is from seeing the grinder pumps coming on line or state doing work. The next step is indoor inspections and dye testing.

Having no further business, the meeting was adjourned at 8:09pm

Respectfully submitted Arlene Miles, Clerk





Sandy Hook Pump Station Upgrade

Newtown Water and Sewer Authority

February 7, 2019


Discussion Outline

- Existing Infrastructure
- Proposed Flows
- Flow Calculations
- Pump Solicitation Phase
- Recommended Pumps
- Generator Evaluation
- Other Recommended Improvements
- Opinion of Construction Cost
- Questions



Existing Infrastructure

- Pump Station
- Submersible Pump Station constructed in 1998
- Two (2) 25 HP Fairbanks Morse Pumps
- Precast Concrete Building House Generator and Controls
- 80KW Generator (120/208V 3 phase)





Force Main Fly Over

Existing Infrastructure

Force Main

 Force main length: 3,120 feet Static Lift: ~145 feet

Interchange, exit 10 bridge only

Parallel 8-inch force main under Pootatuck River and I-84

6-inch ductile iron force main





Proposed Flows

	Average Daily Flow	dy PT	Peak Hourly Floor
	GPD	Meto	DPM
2017 Existing Pump Station Flow	80 788	42	185
Proposed 79 Church HIX Road	22 000	- 5	9
Proposed Fliver Walk	11.988		37
Proposed Fabric Fire Hose Commercial Building	5.000	1	10
TOTAL	121 756	35	307

- Pump station history
- March 2017: Upstream clogged lateral resulted in nearly surcharged pump station
- Draining of high school pool resulted in nearly surcharged pump station

Pump Solicitation Phase

- High head, low flow application
- Three (3) pump manufacturers contacted
- Xylem Flygt
- HOMA
- Fairbank Nujhuis (formerly Fairbank Morse)
- Only one manufacturer could meet specified duty points
- Xylem Flygt



Flow Calculations

- Hazen Williams equation used to calculate head loss through pressurized force main
- Two Hazen Williams coefficients (C factor) used
- C = 91 (calculated based on observed operating flows and pressures)
- C = 120 (industry standard for old ductile iron)
- Need scour velocity greater than 3.0 fps
- Proposed Average Flow 86 gpm; Peak Hour Flow 310gpm
- **Proposed Duty Points**
- 380 gpm @ 260.9 feet (C=91)
- 380 gpm @ 214.6 feet (C=120)
- Scour velocity at proposed duty point = 4.27 fps±
- Existing Pump Duty Point: 200 gpm @ 165 feet

Recommended Pumps

- Xylem Flygt pumps
- Two (2) 72 HP submersible pumps
- Two (2) ABB variable frequency drives (VFD)
- New level transducer and back up floats
- Need electrical service upgrade to 460V/3 phase (existing 208V/3 phase)





Generator Evaluation

- Existing generator cannot power proposed pumps
- Replace 80kW generator with 200kW
- Due to electrical clearances, generator shall be sited





Other Recommended Improvements

- Enlarge existing wet well hatch to sdund accommodate new
- valve chamber Replace valves and fittings in existing
- net valve chamber safety Provide wet well and





Proposed Generator

- Kohler Power Systems 200 kW Generator
- Sized for starting pumps across the line in the event that both line power and VFDs are out of service (similar setup to other pump stations in Town)
- Sited on concrete pad and in sound/weather enclosure



Opinion of Project Cost

	9
	HIME
	HME
	HHE
	ME
Ī	
	The second secon
1 1 A 1 A 1	
10000	THE PARTY NAMED IN COLUMN TWO IS NOT THE OWNER.
3 17 1	
	To promote the factor of the second s
A Market A	Control of the second s
Management of a literal literature	
SCORPTION WE'AS UNITS UNITS COST	
	WO1148ED630

Contact Information

Kurt Mailman, P.E. Vice President

kmailman@fando.com

Douglas Brisee P.E.

Senior Project Engineer dbrisee@fando.com

Fuss & O'Neill, Inc. 146 Hartford Road Manchester, CT 06040 (800) 286-2469 x5273

www.fando.com

Opinion of Project Cost

- Electrical


DESCRIPTION	SYJM	SIRM		URBIT		COSI
Excreal			Т		Ш	
Electrical Demolition	ES.	_	00	7,500.00 \$	••	7,500 00
Provide 200KW Sound Attenuating Generator & Transfer Switch	S	-	00	75 000 00 \$	44	75 000 00
Concrete Pad for Generator	LS.	-	97	7,500.00 \$	97	7,500 00
How Branch Curous Wiring	ÇG.	_	69	10 000 00 \$ 10 000 00	49	10 000 0
Electrical Connections	5	_	87	10,000 00	97	10,000 00
Electrical installation	S	_	01	13 000 00 \$	40	13 000 00 11

Opinion of Project Cost Mechanical

National Party of the Party of	541	041	PER	TVIOI
DESCRIPTION	MEAS	MATS	UPRT	COST
Mechanical				
Mechanical Demoldon	13	-	\$ 6,000,00	8 8 000 00
Two (2) 72HP Submersible Pumps with base ethoes, endellaten excessores, VFDs, Controls and Control Penel	is.	-	\$ 156,000,00	\$ 155 000 00
New Radings for Wastewater Submersate Pumps				
Washwaler Bypass from Temporary Well Well to Force Main	155	-	\$ 5,000,00	An Anna &
4-righ Charps Valva	וצ	- -	l l	l l
4-nch Plug Valve	FA LS		1 1 1	
	CA FA IS	N	30,000 00 2,000 00 2,000 00	1 [] [
4 exch Surgo Relief Valve	EA FA IS	- 2	3,000 00 30,000 00 2,000 00 2,000 00 8,500 00	
Figured Irranovements (Spool preces, Ribrigs, etc.)	5 5 5 5	2	3,000 00 30,000 00 2,000 00 2,000 00 8,500 00 5,000 00	

Opinion of Project Cost - Structural, Site Work, Other

MEM	THE	Ö	7	PER	ا_	MIOI
DESCRIPTION	EV. MI	Utais		TREE	_	COSI
			Г			L
Brychra			Γ			
Provide Well Well and Valve Chamber Sality Fiel	8	2	85	250 00	97	500 00
Modely Existing Woll Woll Operang and Flow Health	LS	-	92	10,000 00 \$	1 1	10,000.00
Sity Work						
function souther for coop) Stramavorphi etc. Superdiscoter			_			
sealts or Town Property Itemsfer/yale regredeng)	rs.	-	69	\$ 000 000 C	47	3,000,00
Other			Ī			
	A	_	14	3 000 000 \$	M.	3 000 00
Survey/An-Built Maggang	15	-	*	2 000 00 \$	**	2 000 00
Contractor's Overhead and Profit	g	15%	99	50,000,00 \$	50	50 000 00
	Service Services	A STATE OF THE P. LEWIS CO.	-	Total Structural Side Work & Other Cost - 5 76 500 00	19	00 00 35



Date (1/1/2018 to 1/31/2019)
/ Hawleyville PS Flow